

[illegible]

QD1		
	P	FP
ILUMINAÇÃO	2.640,00	1,00
TGS	8.400,00	0,8
AR CONDICIONADO	20.520,00	1,00
CHUVEIRO	12.000,00	1,00
POTENCIA TOTAL W	43.560,00	41.880,00

QD1	
FATOR DE DEMANDA	PONTENCIA
0,4	3.744,00
0,5	16.260,00
POTENCIA DEMANDA	20.004,00

QD2		
	P	FP
ILUMINAÇÃO	2.664.00	2.664.00
TTS	18.175.00	0.80
MACROONDAS	3.000.00	1.00
CHAVEIRO	12.000.00	1.00
POTENCIA TOTAL W	35.838.00	32.204.00

QD2	
FATOR DE DEMANDA	PONTENCIA
0.4	6.881,60
0.5	7.500,00
POTENCIA DEMANDA	14.381,60

[illegible]

QD3		
	P	FP
ILUMINAÇÃO	2,676.00	2,676.00
TGS	7,860.00	0.80
AR CONDICIONADO	11,140.00	1.00
CHAVEIRO	12,000.00	1.00
MICRONDAS	1,500.00	1.00
POTENCIA TOTAL W	35,176.00	33,604.00

QD3	
FATOR DE DEMANDA	PONTENCIA
0,4	3.585,60
0,5	12.320,00
POTENCIA DEMANDA	15.905,60

[illegible]

QD4		
	P	FP
TGS	14.400,00	11.520,00
AR CONDICIONADO	17.730,00	17.730,00
CHUIVERO	12.000,00	12.000,00
POTENCIA TOTAL W	44.130,00	41.250,00

QD4	
FATOR DE DEMANDA	PONTENCIA
0,4	4.608,00
0,5	14.865,00
POTENCIA/DEMANDA	19.473,00

[illegible]

	QD6	
	P	FP
QD1	43,560.00	32,204.00
QD2	35,839.00	32,204.00
QD3	35,176.00	33,604.00
QD4	44,130.00	41,250.00
TOTAL	158,705.00	139,262.00

QD6	
	PONTENCIA
QD1	20.004,00
QD2	14.381,60
QD3	15.905,60
QD4	19.473,00
TOTAL	69.764,20

